

Portland, OR Microbiology/Chemistry (c)

Corvallis, OR Microbiology/Chemistry (d) 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e) 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Burton Water Company Reference Number: 20-25615

11511 98th Ave SW Project: Asbestos

Vashon, WA 98070

Date Collected: 7/29/20 15:45 Field ID:

System ID Number: System Group Type:

Lab Number: 186-48588 System Name: Sample Location: S07-2 County:

Sample Purpose: Investigative or Other Source Number:

Sample Composition: Multiple Sources:

Approved by: bj Date Received: 7/30/20 Authorized by: Report Date: 8/20/20

Sample Type: Sampled By: Nick Simmons Lawrence J Henderson, PhD

Director of Laboratories, Vice President Sampler Phone:

				T			T				
DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
0	ASBESTOS	ND	MFL>10um	0.20		7	wf	100.2		08/18/20	Analyzed by EMSL

## NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank

MCL value indicates a level is not currently established.

Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.

ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).