



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



OR NELAP 4072

INORGANIC COMPOUNDS (IOC) REPORT


Client Name: **Burton Water Company**
 10930 SW 238th St.
 Vashon, WA 98070

Reference Number: **19-29620**
 Project: **Water Test**

Date Collected: **8/7/19 15:45**
 System ID Number: **09800L**
 Lab Number: **046-57477**
 Sample Location: **STA A.**
 Sample Purpose: **C - Compliance**
 Sample Composition:

Field ID:
 System Group Type: **A**
 System Name: **BURTON WATER COMPANY INC**
 County: **King**
 Source Number: **S06**
 Multiple Sources:
 Date Received: **8/8/19**
 Report Date: **8/26/19**
 Sample Type: **A - After treatment**
 Sampled By: **E. Simmons**
 Sampler Phone:

Approved by: **ajw,bj,bsp,hkl**
 Authorized by:


Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
	EPA Regulated										
4	ARSENIC	ND	mg/L	0.001	0.010	0.010	bj	200.8	a	08/13/19	
5	BARIIUM	0.004	mg/L	0.001	2	2	bj	200.8	a	08/13/19	
6	CADMIUM	ND	mg/L	0.001	0.005	0.005	bj	200.8	a	08/13/19	
7	CHROMIUM	0.001	mg/L	0.001	0.1	0.1	bj	200.8	a	08/13/19	
11	MERCURY	ND	mg/L	0.0002	0.002	0.002	hkl	245.1	a	08/19/19	
12	SELENIUM	ND	mg/L	0.002	0.05	0.05	bj	200.8	a	08/13/19	
110	BERYLLIUM	ND	mg/L	0.0003	0.004	0.004	bj	200.8	a	08/13/19	
111	NICKEL	ND	mg/L	0.001	0.1		bj	200.8	a	08/13/19	
112	ANTIMONY	ND	mg/L	0.001	0.006	0.006	bj	200.8	a	08/13/19	
113	THALLIUM	ND	mg/L	0.0001	0.002	0.002	bj	200.8	a	08/13/19	
116	CYANIDE, AVAILABLE	ND	mg/L	0.010	0.2	0.2	bsp	OIA-1677-DW	a	08/15/19	
19	FLUORIDE	ND	mg/L	0.1	2	4	ajw	300.0	a	08/08/19	
114	NITRITE-N	ND	mg/L	0.1	0.5	1	ajw	300.0	a	08/08/19 19:34	
20	NITRATE-N	1.63	mg/L	0.1	5	10	ajw	300.0	a	08/08/19 19:34	
161	TOTAL NITRATE/NITRITE	1.63	mg/L	0.50	5	10	ajw	300.0	a	08/08/19 19:34	
	EPA Regulated (Secondary)										
8	IRON	ND	mg/L	0.100	0.3	0.3	hkl	200.7	a	08/22/19	
10	MANGANESE	ND	mg/L	0.001	0.05	0.05	bj	200.8	a	08/13/19	
13	SILVER	ND	mg/L	0.001	0.05	0.05	bj	200.8	a	08/13/19	
21	CHLORIDE	4.8	mg/L	0.1	250	250	ajw	300.0	a	08/08/19	
22	SULFATE	11.1	mg/L	0.2	250	250	ajw	300.0	a	08/08/19	
24	ZINC	ND	mg/L	0.005		5.00	bj	200.8	a	08/13/19	
14	SODIUM	6.49	mg/L	5.0			hkl	200.7	a	08/22/19	
15	HARDNESS as Calcium Carbonate	62.2	mg/L	10			hkl	200.7	a	08/22/19	
16	ELECTRICAL CONDUCTIVITY	155	uS/cm	10	700	700	hkl	SM2510 B	a	08/14/19	
17	TURBIDITY	0.13	NTU	0.10		1	bsp	180.1	a	08/08/19 16:46	
18	COLOR	ND	Color Units	5	15	15	bsp	SM2120 B	a	08/08/19 16:41	
26	TOTAL DISSOLVED SOLIDS (TDS)	106	mg/L	10	500	500	ajw	SM2540 C	a	08/15/19	
	State Unregulated										
9	LEAD	ND	mg/L	0.001		0.015	bj	200.8	a	08/13/19	
23	COPPER	0.005	mg/L	0.005		1.3	bj	200.8	a	08/13/19	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
 An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
 If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.